

THOMSON REUTERS

**WESTLAW** California Code of Regulations[Home Table of Contents](#)

**§ 906.4. Forms.**  
19 CA ADC § 906.4  
BARCLAYS OFFICIAL CALIFORNIA CODE OF REGULATIONS

Barclays Official California Code of Regulations [Currentness](#)  
Title 19. Public Safety  
Division 1. State Fire Marshal  
Chapter 5. Automatic Fire Extinguishing Systems  
Article 6. Labels, Tags and Forms

19 CCR § 906.4

**§ 906.4. Forms.**

(a) The forms in Table 906.4(a) in the format developed by the Office of the State Fire Marshal, which are hereby incorporated by reference, shall be used to record the results of all inspections, testing, and maintenance of water-based fire protection systems. The completed forms shall be provided to the authority having jurisdiction as indicated in Table 906.4(a).

**Table 906.4(a) California State Fire Marshall Automatic Extinguishing Systems (AES) Forms (all forms dated 9-3-2013)**

| Form Number              | Description                                       | Frequency        | Retained On-Site | Forward to AHJ |
|--------------------------|---|------------------|------------------|----------------|
| AES 1                    | Inspection, Testing, and Maintenance Cover Sheet  |                  | X                | X              |
| <b>Sprinkler Systems</b> |   |                  |                  |                |
| AES 2.1                  | Wet Pipe Fire Sprinkler System                    | Quarterly/Annual | X                |                |
| AES 2.2                  | Wet Pipe Fire Sprinkler System                    | Five Year        | X                | X              |
| AES 2.3                  | Dry Pipe Fire Sprinkler System                    | Quarterly/Annual | X                |                |
| AES 2.4                  | Dry Pipe Fire Sprinkler System                    | Five Year        | X                | X              |
| AES 2.5                  | Pre-action Sprinkler Systems                      | Quarterly/Annual | X                |                |
| AES 2.6                  | Pre-action Sprinkler Systems Water                | Five Year        | X                | X              |
| AES 2.7                  | Deluge Sprinkler Systems Water Spray              | Quarterly/Annual | X                |                |
| AES 2.8                  | Deluge Sprinkler Systems Water Spray              | Five Year        | X                | X              |
| AES 2.9                  | Main Drain Test Continuation Form ¥               |                  | ¥                | ¥              |
| AES 3                    | Standpipe and Hose System                         | Quarterly/Annual | X                |                |
| AES 3.1                  | Standpipe and Hose System                         | Five Year        | X                | X              |
| AES 4                    | Private Fire Service Main                         | Quarterly/Annual | X                |                |
| AES 4.1                  | Private Fire Service Main                         | Five Year        | X                | X              |
| <b>Fire Pumps</b>        |   |                  |                  |                |
| AES 5.1                  | Diesel Fire Pump                                  | Weekly           | X                |                |
| AES 5.2                  | Diesel Fire Pump                                  | Annual           | X                |                |
| AES 5.3                  | Electric Fire Pump                                | Monthly          | X                | X              |
| AES 5.4                  | Electric Fire Pump                                | Annual           | X                | X              |
| <b>Other Forms</b>       |   |                  |                  |                |
| AES 6                    | Water Storage Tanks                               | Annual           | X                | X              |
| AES 7                    | Water Spray Fixed System                          |                  | X                | X              |
| AES 8                    | Foam-Water Sprinkler System                       |                  | X                | X              |
| AES 9                    | Continuation Form for Deficiencies and Comments ¥ |                  | ¥                | ¥              |
| AES 10                   | Corrective Action and Repairs Performed ¥         |                  | ¥                | ¥              |

Note:

1. AES-1 shall be attached and maintained as applicable to AES Forms 2 through 8.
  2. AES-9 (when attached) shall be maintained as applicable to AES forms 2 through 8.
  3. The local Fire Code or Building Code official may require additional AES forms to be submitted based on protected hazard and/or complexity.
  4. Any critical deficiency of a fire protection system shall result in the appropriate AES form being sent to the Fire Code or Building Code official
- ¥ Form will only be sent to AHJ if needed.

(b) The forms in Table 906.4(b) in the format developed by the Office of the State Fire Marshal, which are hereby incorporated by reference, shall be used to record the results of all inspections, testing, and maintenance of engineered and pre-engineered fire protection systems. The completed forms shall be provided to the authority having jurisdiction as indicated in Table 906.4(b).

**Table 906.4(b) Inspections, Tests and Maintenance of Engineered and Pre-Engineered Fire Protection Systems (all forms dated 9-3-2013)**

| Form Number | Description   | Frequency   | Maintain on Site | Forward to AHJ |
|-------------|---|-------------|------------------|----------------|
| AES 20      | Wet Chemical Pre-Engineered Fire Extinguishing System             | Semi-Annual | X                | X              |
| AES 21      | Dry Chemical Pre-Engineered Fire Extinguishing System             | Semi-Annual | X                | X              |
| AES 22      | Specialty Pre-Engineered and Engineered Fire Extinguishing System | Semi-Annual | X                | X              |

(c) The following forms in the format developed by the Office of the State Fire Marshal, which are hereby incorporated by reference, shall be used for applications and renewals.

- (1) Application for Weekly Fire Pump Test Certificate (dated August 27, 2009).
- (2) Renewal Application Weekly Fire Pump Test Certificate (dated August 27, 2009).
- (3) Limited License Tool Checklist (AES 11 dated August 19, 2009).
- (4) Limited License Local Fire Authority Endorsement (AES 12 dated August 19, 2009).

(d) If approved by the authority having jurisdiction all inspection, testing, and maintenance can be submitted electronically.

Note: Authority cited: Section 13195, Health and Safety Code. Reference: Section 13195, Health and Safety Code. Authority cited: Section 13195, Health and Safety Code. Reference: Section 13195, Health and Safety Code.

#### HISTORY

1. Renumbering and amendment of former section 906.3 to new subsection 906.4 filed 8-28-2014; operative 8-28-2014 pursuant to Government Code section 11343.4(b)(3) (Register 2014, No. 35).

This database is current through 1/6/17 Register 2017, No. 1

19 CCR § 906.4, 19 CA ADC § 906.4

END OF DOCUMENT

© 2017 Thomson Reuters. No claim to original U.S. Government Works.