



FATS, OILS, GREASE CHECKLIST

In order for the City to provide you complete and expeditious service, the plans and documents indicated below must be provided in order for us to properly log in your application and distribute it to the reviewing departments. Omission of any required information will be deemed an incomplete submittal and returned to the applicant. All forms can be obtained from www.modestogov.com/development/forms

1. Submitted by: _____
2. Accepted by: _____
3. Name of project: _____
4. Address or legal description: _____
5. The following submittal requirements apply:

- [Wastewater Discharge Survey Form](#)
- Proposed menu
- Floor plan
- Kitchen equipment plan
- Plumbing plan
- Diagram of the grease interceptor and sample box (show inlet and outlet lines)
- A minimum 750 gallon interceptor is required
- Show a sampling chamber immediately after the interceptor
- A minimum 8" elevation difference is required between inlet and outlet
- Floor drains, sinks, garbage wash racks, dishwashers, and similar equipment shall be connected to interceptor
- Restrooms, showers, drinking fountains, condensate shall not be connected to interceptor