

Blank or Unassigned cost estimate cells indicate further design requirements or modification by original vendor.

Facility	Record Number	Category	Item	Estimated Cost	Code Reference	Progress	Projected Completion Date	Actual Completion Date	Actual Cost
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28239	Parking	Parking Lot Warnings	\$300.00	CA 11B-502.6.2	Completed	12/14/16	12/14/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28244	Parking	Accessible Signage	\$250.00	ADA 502, 502.6, 703.7.2.1, CA 11B-502.6, 703.7.2.1	Completed	12/14/16	12/14/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28245	Parking	Parking Lot Warnings	\$300.00	CA 11B-502.6.2	Completed	12/14/16	12/14/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	29061	Parking	Accessible Signage	\$250.00	ADA 502, 502.6, 703.7.2.1, CA 11B-502.6, 703.7.2.1	Completed	12/14/16	12/14/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28251	Parking	Parking Lot Warnings	\$300.00	CA 11B-502.6.2	Completed	12/14/16	12/14/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	29062	Parking	Accessible Signage	\$250.00	ADA 502, 502.6, 703.7.2.1, CA 11B-502.6, 703.7.2.1	Completed	12/14/16	12/14/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28255	Parking	Parking Lot Warnings	\$300.00	CA 11B-502.6.2	Completed	12/14/16	12/14/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	29063	Parking	Accessible Signage	\$250.00	ADA 502, 502.6, 703.7.2.1, CA 11B-502.6, 703.7.2.1	Completed	12/14/16	12/14/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28259	Parking	Parking Lot Warnings	\$300.00	CA 11B-502.6.2	Completed	12/14/16	12/14/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28199	Doors	Door Opening Pressure	\$25.00	ADA 404.2.9, CA 11B-404.2.9	Completed	3/1/16	3/16/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28216	Doors	Door Opening Pressure	\$25.00	ADA 404.2.9, CA 11B-404.2.9	Completed	3/1/16	3/16/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28227	Doors	Door Opening Pressure	\$25.00	ADA 404.2.9, CA 11B-404.2.9	Completed	3/1/16	3/16/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	28278	Doors	Door Opening Pressure	\$25.00	ADA 404.2.9, CA 11B-404.2.9	Completed	3/1/16	3/16/16	\$0.00
Amtrak Station - 1700 Held Drive Modesto, CA 95355	29067	Signage	Directional or Information Signage	\$158.00	ADA 216, 216.3, 703, 703.5, CA 11B-216.3, 703.5	Completed	12/14/16	12/14/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28412	Parking	Access Aisle	\$180.00	CA 11B-502.3.4	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28418	Parking	ISA is Faded or Damaged	\$117.00	ADA 502, CA 11B-502.6.4	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28415	Parking	Vehicle Encroaches Into Path of Travel	\$250.00	ADA 502, 502.7, CA 11B-502.7.2	Completed	6/1/16	6/1/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28414	Parking	Outline is Faded, Damaged or Missing	\$350.00	ADA 502, 502.2, CA 11B-502.2	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28420	Parking	Outline is Faded, Damaged or Missing	\$350.00	ADA 502, 502.2, CA 11B-502.2	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28424	Parking	Vehicle Encroaches Into Path of Travel	\$250.00	ADA 502, 502.7, CA 11B-502.7.2	Completed	6/1/16	6/1/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28425	Parking	Parking Space Length	\$350.00	CA 11B-502.2	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28427	Parking	ISA is Faded or Damaged	\$117.00	ADA 502, CA 11B-502.6.4	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28434	Parking	Access Aisle - "No Parking"	\$250.00	CA 11B-502.3.3	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28433	Parking	Access Aisle	\$180.00	CA 11B-502.3.4	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28422	Parking	Outline is Faded, Damaged or Missing	\$350.00	ADA 502, 502.2, CA 11B-502.2	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28309	Doors	Door Opening Pressure	\$25.00	ADA 404.2.9, CA 11B-404.2.9	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28353	Doors	Door Opening Pressure	\$25.00	ADA 404.2.9, CA 11B-404.2.9	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28366	Doors	Door Opening Pressure	\$25.00	ADA 404.2.9, CA 11B-404.2.9	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28388	Doors	Door Opening Pressure	\$25.00	ADA 404.2.9, CA 11B-404.2.9	Completed	5/2/16	5/2/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28311	Signage	Accessible Element/Entrance Signage	\$158.00	ADA 216.2, 216.6, CA 11B-216.2, 216.6	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28348	Signage	Accessible Element/Entrance Signage	\$158.00	ADA 216.2, 216.6, CA 11B-216.2, 216.6	Completed	3/1/16	3/1/16	\$0.00

Transportation Center - 1029 9th Street	Modesto, CA 95354	28389	Signage	Accessible Element/Entrance Signage	\$158.00	ADA 216.2, 216.6, CA 11B-216.2, 216.6	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28293	Restrooms	Width Between Urinal Shields	\$230.00	ADA 305.3, 605, 605.3	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28295	Restrooms	Wall Signage	\$158.00	ADA 216, 216.8, 703, CA 11B-216.8	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28294	Restrooms	Door Signage Height	\$158.00	CA 11B-703.7.2.6	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28289	Restrooms	Lavatory Apron Height	\$2,500.00	ADA 213, 306.3, 606, CA 11B-306.3.3, 606.2	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28290	Restrooms	Lavatory Pipes Wrapping	\$149.00	ADA 213, 606, 606.5, CA 11B-606.5	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28291	Restrooms	Lavatory - Supply Lines Wrapping	\$149.00	ADA 213, 606, 606.5, CA 11B-606.5	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28301	Restrooms	Toilet Compartment Door	\$4,000.00	ADA 213, 404, 604, 604.8, CA 11B-604.8, 604.8.1	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28300	Restrooms	Toilet Compartment Width	\$4,000.00	ADA 213, 603, 604, 604.8.1.1, CA 11B-604.8.1.1	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28307	Restrooms	Rear Grab Bar Length	\$267.00	ADA 603, 604.5.2, 609, CA 11B-604.5.2	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28306	Restrooms	Distance from Front Edge of Toilet to Front of Grab Bar	\$267.00	CA 11B-604.5.1	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28305	Restrooms	Distance from Back Wall to Front of Grab Bar	\$267.00	ADA 603, 604.5.1, 609, CA 11B-604.5.1, 609	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28308	Restrooms	Toilet Paper Dispenser Interferes with Grab Bar	\$277.00	ADA 603, 609.3, CA 11B-309.4, 609.3	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28302	Restrooms	Toilet Distance From Wall	\$2,500.00	ADA 603, 604.2, CA 11B-604.2	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28365	Restrooms	Wall Signage	\$158.00	ADA 216, 216.8, 703, CA 11B-216.8	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28364	Restrooms	Door Signage Height	\$158.00	CA 11B-703.7.2.6	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28362	Restrooms	Lavatory Pipes Wrapping	\$149.00	ADA 213, 606, 606.5, CA 11B-606.5	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28363	Restrooms	Lavatory - Supply Lines Wrapping	\$149.00	ADA 213, 606, 606.5, CA 11B-606.5	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28360	Restrooms	Dispenser Height	\$277.00	ADA 205, 308, 308.1, 309, 606, CA 11B-603.5	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28361	Restrooms	Dispenser Height	\$277.00	ADA 205, 308, 308.1, 309, 606, CA 11B-603.5	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28439	Restrooms	Toilet Compartment Width	\$4,000.00	ADA 213, 603, 604, 604.8.1.1, CA 11B-604.8.1.1	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28396	Restrooms	Compartment Door Handle	\$250.00	ADA 213, 404, 604, 604.8, 604.8.1.2, CA 11B-404.2.7, 604.8.1.2	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28398	Restrooms	Toilet Compartment Door	\$4,000.00	ADA 604.8.1.2, CA 11B-604.8.1.2	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28394	Restrooms	Rear Grab Bar Length	\$267.00	ADA 603, 604.5.2, 609, CA 11B-604.5.2	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28392	Restrooms	Distance from Back Wall to Front of Grab Bar	\$267.00	ADA 603, 604.5.1, 609, CA 11B-604.5.1, 609	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28393	Restrooms	Distance from Front Edge of Toilet to Front of Grab Bar	\$267.00	CA 11B-604.5.1	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28401	Restrooms	Toilet Paper Dispenser Interferes with Grab Bar	\$277.00	ADA 603, 609.3, CA 11B-309.4, 609.3	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28391	Restrooms	Toilet Distance From Wall	\$2,500.00	ADA 603, 604.2, CA 11B-604.2	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28331	Drinking Fountains	Knee Clearance	\$2,500.00	ADA 211, 306, 602, 602.2, CA 11B-306, 602.2	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street	Modesto, CA 95354	28333	Drinking Fountains	Alcove Clear Floor Space Width	\$108.00	ADA 305, 305.7.1, 602.2	Completed	3/1/16	3/1/16	\$0.00

Transportation Center - 1029 9th Street Modesto, CA 95354	28332	Drinking Fountains	Stream Height	\$2,500.00	ADA 211, 602, 602.6, CA 118-211, 602	Completed	3/1/16	3/1/16	\$0.00
Transportation Center - 1029 9th Street Modesto, CA 95354	28330	Drinking Fountains	Fountain Type	\$2,500.00	ADA 211.2, 305, 602, CA 118-211.2, 602	Completed	3/1/16	3/1/16	\$0.00